

## Findings Field Observations

**Project Name:** Schmeikel Boy Sausages

**Project Number:** 12345 - 2

### Zone: Pork Rendering

**Filter Installed:** Yes  
**Correct Filter Size:** No  
**Pan:** Biological Growth  
**Ductwork:** Mold Growth  
**Filter Type:** Fibrous  
**Filter Dust Load:** Moderate  
**Condensate Lines:** Leaks  
**Blower:** Heavy Dust Load  
**Indoor/ Outdoor:** Indoor  
**Coil:** Mold Growth  
**HVAC Notes:** Caution: Boiling Pig Carcass Area

### Area Type: Living Room

**Walls:** Drywall  
**Floors:** Carpet Glued  
**Baseboards:** Vinyl  
**Ceiling:** Drop Down  
**Suspect Asbestos:** Baseboards, Ceiling  
**Dust Load:** Minor  
**Odor:** Musty-strong  
**Temperature:** 74  
**Relative Humidity:** 51  
**CO<sub>2</sub>** 1400

### Damage Type: Water Damage

**Finding ID:** BD32AEE1-98D4-44F0-B439-0590209EB892  
**Finding Date:** 2/25/2007  
**Direction:** NW  
**Affected Area:** Walls  
**Affected Area Size:** 100  
**Affected Area Unit:** Sq Ft  
**Temperature:** 71  
**Relative Humidity:** 44  
**Recommendations:** Remove all damaged dry wall at least 2 feet past the damaged area. Clean all wood or metal studs

### Equipment Used: Air Pump

**Reference Data:** 55  
**Reference Units:** ppb  
**Actual Data:** 56  
**Actual Units:** ppb  
**Sample Name:** 345678  
**Sample ID:** 5

<b>Project Name:</b> Schmeikel Boy Sausages	<b>Inspection Date:</b> 1/1/2007	<b>Event ID:</b> D47AE19D-FB20-43CB-8ACA-434E97DC5AE2
<b>Project Number:</b> 12345 - 2		<b>City:</b> Chicago <b>State:</b> IL <b>Zip:</b> 60605
<b>Site Address:</b> 425 E McFetridge Dr		<b>Lat:</b> 41.8649893423434 <b>Lon:</b> -87.6183550653931
<b>Lot Number:</b> 666	<b>Parcel:</b> Undeveloped # 3	

**Project Name:** Schmeikel Boy Sausages  
**Project Number:** 12345 - 2

---

**Zone:** Pork Rendering

**Filter Installed:** Yes  
**Correct Filter Size:** No  
**Pan:** Biological Growth  
**Ductwork:** Mold Growth  
**Filter Type:** Fibrous  
**Filter Dust Load:** Moderate  
**Condensate Lines:** Leaks  
**Blower:** Heavy Dust Load  
**Indoor/ Outdoor:** Indoor  
**Coil:** Mold Growth  
**HVAC Notes:** Caution: Boiling Pig Carcass Area

---

**Area Type:** Rendering Room

**Area Name:** Render Area 1  
**Walls:** Concrete  
**Floors:** Concrete  
**Baseboards:** Other  
**Ceiling:** Other  
**Suspect Asbestos:** Baseboards  
**Dust Load:** Minor  
**Odor:** Musty-strong  
**Temperature:** 74  
**Relative Humidity:** 55  
**CO<sub>2</sub>** 1400

---

**Damage Type:** Suspect Visible Mold

**Finding ID:** 8B76283D-12BA-4C66-863B-2701D496EEDB  
**Finding Date:** 2/25/2007  
**Direction:** NW  
**Affected Area:** Walls  
**Affected Area Size:** 8'x10'  
**Affected Area Unit:** Ft  
**Temperature:** 80  
**Relative Humidity:** 50  
**Recommendations:** Remove all damaged dry wall at least 2 feet past the damaged area. Clean all wood or metal studs

---

**Equipment Used:** Air Pump

**Sample Name:** 234567  
**Sample ID:** 4

---

<b>Project Name:</b> Schmeikel Boy Sausages	<b>Inspection Date:</b> 1/1/2007	<b>Event ID:</b> D47AE19D-FB20-43CB-8ACA-434E97DC5AE2
<b>Project Number:</b> 12345 - 2		<b>City:</b> Chicago <b>State:</b> IL <b>Zip:</b> 60605
<b>Site Address:</b> 425 E McFetridge Dr		<b>Lat:</b> 41.8649893423434 <b>Lon:</b> -87.6183550653931
<b>Lot Number:</b> 666	<b>Parcel:</b> Undeveloped # 3	

**Project Name:** Schmeikel Boy Sausages  
**Project Number:** 12345 - 2

---

**Zone:** Pork Rendering

**Filter Installed:** Yes  
**Correct Filter Size:** No  
**Pan:** Biological Growth  
**Ductwork:** Mold Growth  
**Filter Type:** Fibrous  
**Filter Dust Load:** Moderate  
**Condensate Lines:** Leaks  
**Blower:** Heavy Dust Load  
**Indoor/ Outdoor:** Indoor  
**Coil:** Mold Growth  
**HVAC Notes:** Caution: Boiling Pig Carcass Area

---

**Area Type:** Rendering Room

**Area Name:** Render Area 1  
**Walls:** Concrete  
**Floors:** Concrete  
**Baseboards:** Other  
**Ceiling:** Other  
**Suspect Asbestos:** Baseboards  
**Dust Load:** Minor  
**Odor:** Musty-strong  
**Temperature:** 74  
**Relative Humidity:** 55  
**CO<sub>2</sub>** 1400

---

**Damage Type:** Warped

**Finding ID:** F4742F8F-586D-4208-AD7E-E858BBEC1F5C  
**Finding Date:** 1/1/2007  
**Direction:** SE  
**Affected Area:** Baseboards  
**Affected Area Size:** 50  
**Affected Area Unit:** Ft  
**Temperature:** 75  
**Relative Humidity:** 56  
**Findings Notes:** Baseboards are warped and sticky  
**Recommendations:** Remove all baseboards. Dry area with fans.

---

**Equipment Used:** Humidity Meter

**Reference Data:** 123  
**Reference Units:** ppb  
**Actual Data:** 456  
**Actual Units:** ppb  
**Sample Name:** 12345  
**Sample ID:** 2  
**Note:** Measurement Note goes here.

---

<b>Project Name:</b> Schmeikel Boy Sausages	<b>Inspection Date:</b> 1/1/2007	<b>Event ID:</b> D47AE19D-FB20-43CB-8ACA-434E97DC5AE2
<b>Project Number:</b> 12345 - 2		<b>City:</b> Chicago <b>State:</b> IL <b>Zip:</b> 60605
<b>Site Address:</b> 425 E McFetridge Dr		<b>Lat:</b> 41.8649893423434 <b>Lon:</b> -87.6183550653931
<b>Lot Number:</b> 666	<b>Parcel:</b> Undeveloped # 3	

**Project Name:** Schmeikel Boy Sausages  
**Project Number:** 12345 - 2

---

**Zone:** Pork Rendering

**Filter Installed:** Yes  
**Correct Filter Size:** No  
**Pan:** Biological Growth  
**Ductwork:** Mold Growth  
**Filter Type:** Fibrous  
**Filter Dust Load:** Moderate  
**Condensate Lines:** Leaks  
**Blower:** Heavy Dust Load  
**Indoor/ Outdoor:** Indoor  
**Coil:** Mold Growth  
**HVAC Notes:** Caution: Boiling Pig Carcass Area

---

**Area Type:** Rendering Room

**Area Name:** Render Area 1  
**Walls:** Concrete  
**Floors:** Concrete  
**Baseboards:** Other  
**Ceiling:** Other  
**Suspect Asbestos:** Baseboards  
**Dust Load:** Minor  
**Odor:** Musty-strong  
**Temperature:** 74  
**Relative Humidity:** 55  
**CO<sub>2</sub>** 1400

---

**Damage Type:** Warped

**Finding ID:** F4742F8F-586D-4208-AD7E-E858BBEC1F5C  
**Finding Date:** 1/1/2007  
**Direction:** SE  
**Affected Area:** Baseboards  
**Affected Area Size:** 50  
**Affected Area Unit:** Ft  
**Temperature:** 75  
**Relative Humidity:** 56  
**Findings Notes:** Baseboards are warped and sticky  
**Recommendations:** Remove all baseboards. Dry area with fans.

---

**Equipment Used:** Air Pump

**Sample Name:** 123456  
**Sample ID:** 3

---

<b>Project Name:</b> Schmeikel Boy Sausages	<b>Inspection Date:</b> 1/1/2007	<b>Event ID:</b> D47AE19D-FB20-43CB-8ACA-434E97DC5AE2
<b>Project Number:</b> 12345 - 2		<b>City:</b> Chicago <b>State:</b> IL <b>Zip:</b> 60605
<b>Site Address:</b> 425 E McFetridge Dr		<b>Lat:</b> 41.8649893423434 <b>Lon:</b> -87.6183550653931
<b>Lot Number:</b> 666	<b>Parcel:</b> Undeveloped # 3	

**Project Name:** Schmeikel Boy Sausages  
**Project Number:** 12345 - 2

---

**Zone:** Pig Storage

**Filter Installed:** Yes

**Pan:** Biological Growth  
**Ductwork:** Has holes  
**Filter Type:** Pig Hair  
**Filter Dust Load:** Significant  
**Condensate Lines:** Leaks  
**Blower:** Rattles  
**Indoor/ Outdoor:** Indoor  
**Coil:** Disgusting  
**HVAC Notes:** A/C smells like pig. Very cold area

---

**Area Type:** Bedroom

**Area Name:** Pig Humping Area  
**Walls:** Drywall  
**Floors:** Concrete  
**Baseboards:** Other  
**Ceiling:** Drop Down  
**Suspect Asbestos:** Ceiling  
**Dust Load:** Significant  
**Odor:** Porky  
**Temperature:** 74  
**Relative Humidity:** 64  
**CO<sub>2</sub>** 1411  
**Area Notes:** Pork Pit

**Damage Type:** Suspect Visible Mold

**Finding ID:** 29059367-93E7-4ECA-BC48-B42A51CB0BAE  
**Finding Date:** 1/1/2007  
**Direction:** SE  
**Affected Area:** Walls  
**Affected Area Size:** 90  
**Affected Area Unit:** Sq Ft  
**Findings Notes:** Enitre SE wall is distressed  
**Recommendations:** Remove or clean all materials with suspect visible mold.

---

**Equipment Used:** Surface Meter

**Sample Name:** 984  
**Sample ID:** 8

---

**Equipment Used:** Surface Meter

**Sample Name:** 94620  
**Sample ID:** 7

---

<b>Project Name:</b> Schmeikel Boy Sausages	<b>Inspection Date:</b> 1/1/2007	<b>Event ID:</b> D47AE19D-FB20-43CB-8ACA-434E97DC5AE2
<b>Project Number:</b> 12345 - 2		<b>City:</b> Chicago <b>State:</b> IL <b>Zip:</b> 60605
<b>Site Address:</b> 425 E McFetridge Dr		<b>Lat:</b> 41.8649893423434 <b>Lon:</b> -87.6183550653931
<b>Lot Number:</b> 666	<b>Parcel:</b> Undeveloped # 3	

Project Name: Schmeikel Boy Sausages  
Project Number: 12345 - 2

**Zone: Pig Storage**

Filter Installed: Yes  
  
Pan: Biological Growth  
Ductwork: Has holes  
Filter Type: Pig Hair  
Filter Dust Load: Significant  
Condensate Lines: Leaks  
Blower: Rattles  
Indoor/ Outdoor: Indoor  
Coil: Disgusting  
HVAC Notes: A/C smells like pig. Very cold area

**Area Type: Bedroom**

Area Name: Pig Humping Area  
Walls: Drywall  
Floors: Concrete  
Baseboards: Other  
Ceiling: Drop Down  
Suspect Asbestos: Ceiling  
Dust Load: Significant  
Odor: Porky  
Temperature: 74  
Relative Humidity: 64  
CO<sub>2</sub>: 1411  
Area Notes: Pork Pit

**Damage Type: Suspect Visible Mold**

Finding ID: 93339234-9DA7-4717-AB12-5C0922BFD333  
Finding Date: 1/1/2007  
Direction: NE  
Affected Area: Walls  
Affected Area Size: 50  
Affected Area Unit: Sq Ft  
Findings Notes: Visible behind wallpaper and in wall cavity through an open cut.  
Recommendations: Remove or clean all materials with suspect visible mold.

**Damage Type: Stained**

Finding ID: DEA205E3-9A8A-4794-B1AE-740D388838A1  
Finding Date: 1/1/2007  
Affected Area: Ceiling  
Affected Area Size: 10  
Affected Area Unit: %  
Findings Notes: Ceiling Tile shows water damage  
Recommendations: Remove all water damaged ceiling tiles to facilitate drying within the wall cavities.

Project Name:	Schmeikel Boy Sausages	Inspection Date:	1/1/2007	Event ID:	D47AE19D-FB20-43CB-8ACA-434E97DC5AE2				
Project Number:	12345 - 2			City:	Chicago	State:	IL	Zip:	60605
Site Address:	425 E McFetridge Dr	Parcel:	Undeveloped # 3	Lat:	41.8649893423434	Lon:	-87.6183550653931		
Lot Number:	666								

**Project Name:** Schmeikel Boy Sausages  
**Project Number:** 12345 - 2

---

**Zone:** Pig Storage

**Filter Installed:** Yes

**Pan:** Biological Growth  
**Ductwork:** Has holes  
**Filter Type:** Pig Hair  
**Filter Dust Load:** Significant  
**Condensate Lines:** Leaks  
**Blower:** Rattles  
**Indoor/ Outdoor:** Indoor  
**Coil:** Disgusting  
**HVAC Notes:** A/C smells like pig. Very cold area

---

**Area Type:** Basement

**Area Name:** Sub Level  
**Walls:** Concrete  
**Floors:** Concrete  
**Baseboards:** Wood  
**Ceiling:** Drop Down  
**Suspect Asbestos:** Ceiling  
**Dust Load:** Moderate  
**Odor:** Musty-light  
**Temperature:** 74  
**Relative Humidity:** 55  
**CO<sub>2</sub>** 1400  
**Area Notes:** Sub level pork pit

**Damage Type:** Wet

**Finding ID:** F5367D18-CDCC-4BEA-AF21-3D69A3EBFFE1  
**Finding Date:** 6/26/2006  
**Direction:** NE  
**Affected Area:** Floor  
**Affected Area Size:** 15  
**Affected Area Unit:** Sq Ft  
**Findings Notes:** wall area adjacent to air handler is wet

---

**Sample ID:** 6

<b>Project Name:</b> Schmeikel Boy Sausages	<b>Event ID:</b> D47AE19D-FB20-43CB-8ACA-434E97DC5AE2			
<b>Project Number:</b> 12345 - 2	<b>Inspection Date:</b> 1/1/2007	<b>City:</b> Chicago	<b>State:</b> IL	<b>Zip:</b> 60605
<b>Site Address:</b> 425 E McFetridge Dr	<b>Parcel:</b> Undeveloped # 3	<b>Lat:</b> 41.8649893423434	<b>Lon:</b> -87.6183550653931	
<b>Lot Number:</b> 666				